

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION
CERTIFICATE.**

No. DL/KSN/JUNE/14Date : 23/06/2026

It is certified that an inspection team headed by Neeraj Kumar
Assistant Engineer (A.E) (Name of Officers
 with designation) from U.P. Jal Nigam (Rural) Kushinagar (Name of
 Department/Office) Inspected the B.T.S. National Public School
Vill- Mahuawa Tamkubiraj Kushinagar (Name & Address of
 the School) on _____ and found that the B.T.S. National
Public School Vill- Mahuawa Tamkubiraj Kushinagar (Name of school) has safe
 drinking water facilities for the students and members of staff of the institution and is maintaining
 the hygienic sanitation condition in the school building & the campus as per the norms
 prescribed by the Central/State/U.T Govt.

The above valid for a period of 1 Year.

Signature with Seal :

 सहायक अभियन्ता
जल निगम ग्रामीण

Name :

Neeraj Kumar

Designation :

A.E U.P. JN(R)
Kushinagar

To

B.T.S. National Public School
Vill- Mahuawa Tamkubiraj
Kushinagar Uttar Pradesh

(Name & Address of the Institution)



**District Level Water analysis
Laboratory**
Uttar Pradesh Jal Nigam (Rural), Kushinagar
Add. -Vill Parsauni Kala Near Water Tank Padrauna
KUSHINAGAR 274304



TC- 17214

Analysis Report							
Report No		DL/KSN/JUNE/14		Date	23.06.2026	Page No	01
Customer Details							
Name and Address		B.J.S. NATIONAL PUBLIC SCHOOL VILL- MAHUAWA TAMKUHIRAJ KUSHINAGAR					
Ref Letter No & Date		NA					
Basic details of sample							
District	KUSHINAGAR		Block	TAMKUHIRAJ			
Gram Panchayat	MAHUAWA		Village	MAHUAWA			
Habitation	MAHUAWA		Location	NEAR MAHUAWA KATA			
Water Source	R.O WATER SAMPLE		Sample Id	KSN /14			
Quantity of Sample	1000ml		Date of S.C.	22.06.2026			
Receiving Date	22.06.2026		S. Collector	KUSUM SINGH			
Sample Depositor	KUSUM SINGH						
Analysis Start Date	23.06.2026		Analysis Completion Date	23.06.2026			
Temperature- 25±3°C			Relative Humidity- 50±15%				
Technical Data of Analysis							
S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values As per BIS 10500:2012			Ref. Method of Analysis	
			Unit	Acceptable Limit	Permissible Limit		
1	2	3	4	5	6		
1	Ph	7.1	...	6.5	8.5	IS 3025(Part 11): 2022	
2	Turbidity (NTU)	0.29	NTU	1.0	5.0	IS 3025(Part 10): 2023	
3	TDS (mg/l)	68.18	mg/L	500	2000	IS 3025(Part 16): 2023	
4	Total Alkalinity (mg/l)	76	mg/L	200	600	IS 3025(Part 23): 2023	
5	Total Hardness (mg/l)	64	mg/L	200	600	IS 3025(Part 21): 2023	
6	Calcium (mg/l)	16	mg/L	75	200	IS 3025(Part 40): 2019	
7	Magnesium (mg/l)	5.83	mg/L	30	100	IS 3025(Part 46): 2019	
8	Chloride (mg/l)	20	mg/L	250	1000	IS 3025(Part 32): 2019	
9	Odour	Agreeable		Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025(Part 5): 2018	
10	Taste	Agreeable		Agreeable/Not Agreeable	Agreeable/Not Agreeable	IS 3025(Part 8): 2023	

#BDL- Below Detection Limit, NA- Not Analyzed.
** Parameter(s) above permissible limit are in bold digits.

Note

- 1.This Certificate refers only to the particular sample (s) submitted for testing.
2. This certificate shall not be re produced, except in full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of under the stated conditions of measurements.
4. Sample will be stored up to 07days (in case of non-perishable item only) from the date of issue of tests reports.
- 5* Parameter Are Not NABL accredited

Manish

Prepared by

Email id- labkushinagar@gmail.com

chandan

Reviewed By

Authorized Signatory

Contact No-9120706093



**District Level Water analysis Laboratory,
Uttar Pradesh Jal Nigam (Rural), Kushinagar
Add. -VillParsauni Kala Near Water Tank Padrauna
KUSHINAGAR 274304**

Analysis Report						
Report No	DL/KSN/JUNE/14		Date	23.06.2026	Page No	01
Customer Details						
Name and Address	B.J.S. NATIONAL PUBLIC SCHOOL VILL- MAHUAWA TAMKUHIRAJ KUSHINAGAR					
Ref Letter No & Date	NA					
Basic details of sample						
District	KUSHINAGAR		Block	TAMKUHIRAJ		
Gram Panchayat	MAHUAWA		Village	MAHUAWA		
Habitation	MAHUAWA		Location	NEAR MAHUAWA KATA		
Water Source	R.O WATER SAMPLE		Sample Id	KSN /14		
Quantity of Sample	1000ml		Date of S.C.	22.06.2026		
Receiving Date	22.06.2026		S. Collector	KUSUM SINGH		
Sample Depositor	KUSUM SINGH					
Analysis Start Date	23.06.2026		Analysis Completion Date	23.06.2026		
Temperature- 25±3°C			Relative Humidity- 50±15%			
Technical Data of Analysis						
S. No.	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values As per BIS 10500:2012			Ref. Method of Analysis
			Unit	Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	
11	Fluoride*	0.12	mg/L	5.00	20.0	IS 3025(Part 60): 2022
12	Nitrate (mg/l)*	0.897	mg/L	5.00	50.0	IS 3025(Part 34): 2022
13	Sulphate (mg/l)*	2.214	mg/L	5.00	50.0	IS 3025(Part 24): 2022
14	Iron (mg/l)*	0.00	mg/L	0.50	5.0	IS 3025(Part 53): 2022
15	Arsenic (mg/l)*	0.00	mg/L	0.005	2.00	IS 3025(BY AAS): 2022
16	Conductivity*		(Ms/cm)	NA	NA	IS 3025(Part 10): 2017
#BDL- Below Detection Limit, NA- Not Analyzed.						
** Parameter(s) above permissible limit are in bold digits.						
Note	1.This Certificate refers only to the particular sample (s) submitted for testing. 2. This certificate shall not be re produced, except in full, unless written permission for the publication of an approved abstract. 3. The test results reported in this certificate are valid at the time of under the stated conditions of measurements. 4. Sample will be stored up to 07days (in case of non-perishable item only) from the date of issue of tests reports. 5* Parameter Are Not NABL accredited					
Prepared by <i>Manish</i>		Reviewed By <i>chandan</i>		Authorized Signatory Prabhat Ranjan (Quality Manager)		
Email id- labkushinagar@gmail.com					Contact No-9120706093	





**District Level Water analysis Laboratory,
Uttar Pradesh Jal Nigam (Rural), Kushinagar
Add. -Vill Parsauni Kala Near Water Tank Padrauna
KUSHINAGAR 274304**

BACTERIOLOGICAL SAMPLE TEST REPORT

Report No	DL/KSN/JUNE/14	Date	23.06.2026	Page No	01
Customer Details					
Name and Address	B.J.S. NATIONAL PUBLIC SCHOOL VILL- MAHUAWA TAMKUHIRAJ KUSHINAGAR				
Ref Letter No & Date	NA				
Basic details of sample					
District	KUSHINAGAR	Block	TAMKUHIRAJ		
Gram Panchayat	MAHUAWA	Village	MAHUAWA		
Habitation	MAHUAWA	Location	NEAR MAHUAWA KATA		
Water Source	R.O WATER SAMPLE	Sample Id	KSN /14		
Quantity of Sample	1000ml	Date of S.C.	22.06.2026		
Receiving Date	22.06.2026	S. Collector	KUSUM SINGH		
Sample Depositor	KUSUM SINGH				
Analysis Start Date	23.06.2026	Analysis Completion Date	23.06.2026		
Temperature- 25±3°C		Relative Humidity- 50±15%			

			Technical Data of Analysis			
S. No.	Analyzed Parameters(Unit of Measurement)	Observed Value	Specified Values As per BIS 10500:2012			Ref. Method of Analysis
			Unit	Acceptable Limit	Permissible Limit	
1	2	3		4	5	6
1	Ph	7.1	...	6.5	8.5	IS 3025(Part 11): 2022
2	Residual Chlorine	0	mg/L	0.2	1.0	IS 3025(Part 26): 1986
3	Total Coliform	0	CFU	0	CFU	APHA 23 Edition ; 2017
4	E- Coli	0	CFU	0	CFU	APHA 23 Edition ; 2017

#BDL- Below Detection Limit, NA- Not Analyzed.

** Parameter(s) above permissible limit are in bold digits.

- Note
1. This Certificate refers only to the particular sample(s) submitted for testing.
 2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract.
 3. The test results reported in this certificate are valid at the time of under the stated conditions of measurements.
 4. Sample will be stored up to 07 days (in case of non-perishable item only) from the date of issue of tests reports.
 - 5* Parameter Are Not NABL accredited

Manish

Prepared by

Email id- labkushinagar@gmail.com

chandan

Reviewed By



Authorized Signatory

Contact No-9120706093